

SPECIFICATION

MODEL DCH – CONDENSATE HOOD

The Duo-Aire hood shall be a Type II wall hood constructed to exhaust steam vapors. Hood shall be constructed of all 300 series stainless steel and shall include a two inch full perimeter gutter with drain to capture and drain the condensate generated. Hood shall also be provided with a baffle the full length of the hood with one inch exhaust air slots to enhance exhaust air flow through the exhaust collar provided. A perforated stainless steel duct protector with removable screen shall be provided.

Hanging brackets shall be welded to each outside corner of hood for contractor installation of hood. Exhaust CFM shall meet requirements of area being exhausted and hood sized to cover exhaust area with appropriate overhangs, as required.

Duo-Aire, Inc. 316 W. Central Avenue, Suite 505, Winter Haven, FL 33880
Phone: 863-294-2272 Fax: 863-294-2704 E-Mail: gregb@ventilationmarketing.com