

SPECIFICATION

MODEL DDW – CONDENSATE HOOD

The Duo-Aire hood shall be a Type II wall hood constructed to exhaust steam vapors. Hood shall be constructed of all 300 series stainless steel and shall include a three inch full perimeter gutter with drain to capture and drain the condensate generated. A perforated stainless steel duct protector shall be provided at top inside of hood with a removable perforated screen. Hanging brackets shall be welded to top corners of hood for use by contractor in installation.

Exhaust CFM shall meet requirements of dish machine model specified. Appropriate hood overhang shall be provided dependent upon exhaust requirement. Hood will be sized in accordance with model number of dish machine.

Duo-Aire, Inc. 316 W. Central Avenue, Suite 505, Winter Haven, FL 33880
Phone: 863-294-2272 Fax: 863-294-2704 E-Mail: gregb@ventilationmarketing.com